

Ind 55.30 Lights and lighting. (1) Electric lights shall be used for lighting where electric current is available. No oil lamps or other open lights shall be used in or about any stage containing scenery.

(2) No gas lighting of any kind shall be used on any stage containing scenery, nor in any property room, storage room, scene dock, or fly gallery, except in localities where electricity is not available.

(3) In all theaters and assembly halls, all stairways, passageways, and exit doors shall be properly lighted and shall remain lighted throughout every performance or entertainment and until the audience has left the building.

Ind 55.32 Sanitary equipment. (1) **TOILETS AND URINALS.** Separate toilet rooms in connection with the auditorium shall be provided for males and females. One water-closet shall be installed for each 200 females or fraction, and one water-closet and one urinal for each 300 males or fraction, assuming the audience to be equally divided between males and females; except that in dance halls there shall be provided one water-closet for each 100 females or fraction, one water-closet for each 300 males or fraction and one urinal for each 150 males or fraction.

(2) **NUMBER OF TOILETS WHERE ALCOHOLIC BEVERAGES ARE SERVED ON PREMISES.** Where stimulating drinks, such as beer, wines and other alcoholic beverages, are served for consumption on the premises, there shall be provided one water-closet for every 40 females, or fraction, one water-closet for every 150 males, or fraction, and one urinal for every 50 males, or fraction; except that where the capacity in such places exceeds 300 persons, the ratio of the number of fixtures to the number of persons accommodated in excess of 300 need be only one-half of the above.

(3) **TOILETS IN CONNECTION WITH STAGE.** There shall be separate water-closets provided for males and females in connection with the stage of every theater and assembly hall which is equipped for the showing of stage productions.

(4) **TOILETS IN CONNECTION WITH MOTION PICTURE BOOTH.** In theaters where motion picture machines are run continuously for a period of more than 2 hours without at least 10 minutes intermission for the motion picture machine operator for each 2 hour period, toilets shall be provided in direct connection with the motion picture booth.

Note: For general toilet room requirements see Wis. Adm. Code sections Ind 52.50 to Ind 52.64, inclusive.

(5) **DRINKING WATER.** Separate drinking fountains of a type approved by the state board of health shall be provided for the stage and auditorium where water supply is available. Drinking fountains shall not be placed in toilet rooms.

(6) **WASHING FACILITIES.** Washbowls shall be provided in connection with toilet rooms, one for every 2 closets and urinals or fraction.

Ind 55.33 Standpipes. Where proper water supply is available, at least one first aid standpipe, as specified in section Ind 51.21, shall be provided on the stage of every theater and assembly hall where a fire curtain is required. Each hose shall be not more than 75 feet long.

and where such hose will not reach every part of the stage section additional hose connections and hose, or additional standpipes, shall be provided.

Ind 55.34 Fire extinguishers. (1) Standard fire extinguishers of an appropriate type as specified in section Ind 51.22 shall be provided for all theaters and assembly halls as follows:

- (a) Two on stage, if scenery is used.
 - (b) One on stage, if no scenery is used.
 - (c) One in motion picture booth, or in ticket office if there is no booth.
 - (d) One in dressing room section.
- (2) Extinguishers shall be properly exposed to view and always accessible.

Ind 55.35 Automatic sprinklers. In every theater and assembly hall where a proscenium curtain is required, approved automatic sprinklers, as specified in section Ind 51.23, shall be provided under the stage, under the stage roof, and in the dressing rooms, but not in the automatic smoke outlet.

Ind 55.39 Use of "safety-base" film. (1) The requirements of sections Ind 55.40 through 55.49 will not apply in buildings in which movie projectors are used with "safety-base" film provided the conditions of (a) and (b) in this subsection are met.

(a) The owner shall submit an affidavit to the Department of Industry, Labor and Human Relations stating that "safety-base" film only will be used in all movie projectors.

(b) The affidavit shall be signed by the owner and the signature notarized.

Note: For definition of "owner" see section 101.01 (13), Wis. Stats. *History:* Cr. Register, April, 1971, No. 184, eff. 5-1-71.

Ind 55.40 Motion picture machine booths, general. Every motion picture machine using nitro-cellulose film, together with all auxiliary and associated equipment, shall be enclosed in a booth so arranged as to permit the operator to walk freely on either side and in back of the machine. At least 48 square feet in area shall be provided for one machine, and 24 square feet additional for each machine over one. The ceiling height shall be not less than 7 feet.

Ind 55.41 Construction of booth. The floor of each motion picture booth shall be constructed of masonry or reinforced concrete, or shall be covered with not less than 2 inches of fire-resistive material. The walls and ceiling shall be not less than 2-hour fire resistive construction as specified in section Ind 51.04.

History: 1-3-56; am. Register, February, 1971, No. 182, eff. 7-1-71.

Ind 55.42 Doors. (1) The door to the booth shall be not larger than necessary for the safe and proper use and maintenance of the booth and equipment, but in no case shall its dimensions be smaller than 2 feet by 5 feet or larger than 3 feet by 7 feet. The top of the door shall be not less than 12 inches below the ceiling of the booth.

Register, April, 1971, No. 184
Building and hearing, ventilating
and air conditioning code